

आवक नं. दिनांक विरिहा सं. Military Engineer Services
Award No. 32 Date 25/6/21 File No. JE Det (Fy)
RPD Complex Military Station
Bhusawal-425203

237/1051 E2 (Fy)

23 Jun 2021

**Kendriya Vidyalaya
Ordnance Factory
Varangaon-425308**

BUILDING SAFETY CERTIFICATE REG

1. Ref your letter No.2748/338/2021-22/KVOFV/89 dated 17 Jun 2021
2. Undersigned visited the school building on 21 Jun 2021 and observed the following
 - (a) Water proofing roof treatment of G+2 bldg needs to be redone
 - (b) Replastering is required in patched at places.
 - (c) Rain water locking near main gate entrance, need some repair work at main drainage
3. Beside above the school buildings are safe from structural point of view.

K. Ramesh

K Ramesh
JE(Civil)
JE(Det)(Fy) Bhusawal

Copy to:-

GE (I) (P) Fy Kirkee - For info please.

*File it
25.6.21.*

अनुक्रम नं. 139 दिनांक 08/06/2021

आयुध निर्माणी वरणगाँव, जिला - जलगाँव - 425 308

Inward No. _____ Date _____ File No. _____

**ORDNANCE FACTORY, VARANGAON Dist -
Jalgaon - 425 308.**

दूरभाष /Tele : 02582.277812 to 817 फैक्स : 02582.277822

ई-मेल /e mail : gmordfy_jal@sancharnet.in

आयुध निर्माणी बोर्ड की एक इकाई

A unit of Ordnance Factory Board

भारतीय आयुध निर्माणियाँ , रक्षा मंत्रालय

Indian Ordnance Factories, Ministry of Defence



No.1257/F/FB

Date : 07.06.2021

विषय : आग की सुरक्षा प्रमाण पत्र मिलने हेतु ।

उपरोक्त विषय के अनुसार केंद्रीय विद्यालय आयुध निर्माणी वरणगाँव में आग की सुरक्षा के संबंधी सभी उपकरणों की उपलब्धता की पुर्तता की गई है । इस पत्र द्वारा यह प्रमाणित किया जाता है कि केंद्रीय विद्यालय आयुध निर्माणी वरणगाँव को आग की सुरक्षा का सुरक्षा प्रमाण पत्र दिया जाता है ।

काशमप
रक्षा
08.6.21

(ए.आर.पाटील)
अग्निशमन अधिकारी
कूते महाप्रबंधक

प्रति



प्राचार्य

केंद्रीय विद्यालय

आयुध निर्माणी वरणगाँव